



Certificate of Compliance

This certificate is issued for the following:

Open Water Spray Nozzles

(see attached configuration table)

Prepared for:

Bete Fog Nozzle Inc
50 Greenfield St,
Greenfield, Massachusetts 01301

Manufactured by:

Bete Fog Nozzle Inc
50 Greenfield St,
Greenfield, Massachusetts 01301

FM Approvals Class: 2025

Approval Identification: 0003049218

Superseded by: RR212592

Date Approved: January 23, 2015

Date Approved: January 29, 2018

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

A handwritten signature in black ink that reads 'D. B. Fuller'.

David B. Fuller
AVP, Manager of Fire Protection
FM Approvals
1151 Boston-Providence Turnpike
Norwood, MA 02062 USA



Member of the FM Global Group



Certificate of Compliance

Model AFF

Model	Nominal K-Factor (gpm/(psi) ^{1/2})	Nominal Spray Angle (Degrees)	Nominal Thread Size (in.)	Finishes
AFF	0.95	145	3/8	Brass, Bronze, Stainless Steel, Titanium and Cobalt, Copper, Nickel, and Tantalum based alloys
AFF	1.18	145	1/2	Brass, Bronze, Stainless Steel, Titanium and Cobalt, Copper, Nickel, and Tantalum based alloys
AFF	1.66	145	1/2	Brass, Bronze, Stainless Steel, Titanium and Cobalt, Copper, Nickel, and Tantalum based alloys
AFF	2.53	145	1/2	Brass, Bronze, Stainless Steel, Titanium and Cobalt, Copper, Nickel, and Tantalum based alloys
AFF	3.35	145	3/4	Brass, Bronze, Stainless Steel, Titanium and Cobalt, Copper, Nickel, and Tantalum based alloys
AFF	4.43	145	3/4	Brass, Bronze, Stainless Steel, Titanium and Cobalt, Copper, Nickel, and Tantalum based alloys
AFF	5.69	145	3/4	Brass, Bronze, Stainless Steel, Titanium and Cobalt, Copper, Nickel, and Tantalum based alloys



Member of the FM Global Group